

Client Name: Milwaukee Public Schools

Report #: 368722

Is this # 15 or more?
↑

Sampling Point: 8-B14

PWS ID: Not Supplied

Metals									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
7439-92-1	Lead	200.8	15 l	1.0	5.8	ug/L	---	08/03/16 20:30	3506367

Sampling Point: 8-B15

PWS ID: Not Supplied

Metals									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
7439-92-1	Lead	200.8	15 l	1.0	53	ug/L	---	08/03/16 20:36	3506368

Sampling Point: 8-B16

PWS ID: Not Supplied

Metals									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
7439-92-1	Lead	200.8	15 l	1.0	270	ug/L	08/04/16 15:45	08/05/16 13:44	3506369

Sampling Point: 8-B17

PWS ID: Not Supplied

Metals									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
7439-92-1	Lead	200.8	15 l	1.0	38	ug/L	---	08/03/16 20:37	3506370

Sampling Point: 8-B18

PWS ID: Not Supplied

Metals									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
7439-92-1	Lead	200.8	15 l	1.0	40	ug/L	---	08/03/16 20:39	3506371

Sampling Point: 8-B20

PWS ID: Not Supplied

Metals									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
7439-92-1	Lead	200.8	15 l	1.0	2.4	ug/L	---	08/03/16 20:41	3506372